

**FIRE EXTINGUISHERS**

**DOCUMENT NUMBER: 10500**

**APPLICATION: ELEMENTARY, MIDDLE AND HIGH SCHOOL**

**DATE OF ISSUE:**

**07-10-00 – deleted fire extinguisher types**

01-27-00 - revised Type A extinguisher listed in notes below

11-14-96 - revised notes below

03-19-93 - first issued

**NOTES:**

Provide fire extinguishers in accordance with all applicable codes.

**All** fire extinguishers are to be housed in recessed or semi-recessed cabinets except for those provided in mechanical/electrical rooms and kitchens, which are to be mounted on brackets.

All extinguishers must be made of metal (no plastic) parts on the valve mechanism.

All extinguishers must be permanently identified with the words "Hills. Co. School Bd."

All extinguishers must be provided with a current inspection tag, by the Contractor, prior to substantial acceptance.

All fire extinguishers are to be located inside buildings. Extinguishers which are required for mechanical rooms, custodial areas, etc., are to be provided in addition to those provided for general use, since those areas will remain locked during the hours when the building is occupied.

Fire extinguishing equipment contained in kitchen hoods must, when activated, be designed to automatically turn off the gas and electricity for all equipment installed under the hood.

**ATTACHMENTS:**

None.